

APPENDIX H

2006 Edition, Published January 1, 2006; Document Revision Date: July 1, 1996

SEWER AUXILIARY METERING SYSTEMS

Requirements and Policies of City of Columbus, Ohio, Division of Sewerage and Drainage.

1. Requests for installation must be in writing from the consumer.
2. Metering systems must measure in cubic meters as manufactured by Badger, Rockwell, Hersey, Worthington, or as approved by Director of Public Service. Obtain a specification sheet from Division of Sewerage and Drainage.
3. The meter(s) must be located downstream (after) and as near the main water meter as possible.
4. Yokes will be used in the metering system installation whenever possible.
5. Provide exterior remote readout register(s) on the side of the structure within two (2) feet of a front corner and four (4) to five (5) feet above the grade line.
6. After installation, a final inspection must be made by personnel from the Division of Sewerage and Drainage office.
7. All sewer auxiliary metering systems shall be plainly identified by serial number, a "S.D." seal and by labeling with either a "SAM-" or "SAM+" label. This will be done by Sewerage Charges Office personnel only.
8. Metering systems, which have had prior use, must be taken to the water meter shop at 640 Dublin Road for recalibration prior to new installation. A used system must measure in cubic meters.

END OF APPENDIX H