



	2011	2012	2013	2014	2015	2016	Goal
Composite Uptime	99.986%	99.873%	99.966%	99.990%	99.982%	99.988%	>99.96%
# Downtime Hours	1086	9845	2681	783	1314	898	<3000
# Occurrences	39	70	92	113	53	36	<92

Individual Utility Uptime	2011	2012	2013	2014	2015	2016	Goal
Steam/Hot Water	99.920%	99.210%	99.860%	99.969%	99.926%	99.972%	>99.70%
Chilled Water	99.980%	99.920%	99.920%	99.965%	99.966%	99.971%	>99.70%
Electric	99.998%	99.994%	99.989%	99.999%	99.999%	99.999%	>99.70%
Domestic Water	99.999%	100.000%	99.995%	99.994%	99.992%	99.988%	>99.70%
Natural Gas	99.990%	99.990%	99.960%	99.990%	99.988%	99.990%	>99.70%
Domestic Hot Water	100.000%	100.000%	100.000%	100.000%	100.000%	99.999%	>99.70%
Compressed Air	99.998%	100.000%	99.978%	100.000%	100.000%	99.999%	>99.70%